



LEGENDE : _____ CABLAGE USINE

□ BORNE DE RACCORDEMENT

_____ CABLAGE INSTALLATEUR

- - - - - SHUNT PUMP DOWN

BORNIER X DE RACCORDEMENT

ALIM. 230VCA	←	PHASE 230V	Noir	1	}
PRESSOSTAT	←	CONTACT	Noir	2	
ELECTROVANNE	←	PHASE 230V	Noir	3	
RESISTANCES CARTER	←	PHASE 230V	Noir	4	
PRESSOSTAT	←	CONTACT	Noir	5	}
ALARME	←	PHASE 230V	Noir	6	
VENTILATION EVAP.	←	PHASE 230V	Noir	7	
ALIM. 230VCA	←	NEUTRE 230V	Bleu	N	}
ELECTROVANNE	←	NEUTRE 230V	Bleu	N	
RESISTANCES CARTER	←	NEUTRE 230V	Bleu	N	
GROUPE MONO	←	PHASE 230V	Noir	8	L
GROUPE MONO	←	NEUTRE 230V	Bleu	9	N

Shunt 1&2 = Avec Pump Down
Shunt 2&3 = Sans Pump Down

NEUTRE 230V → VENTILATION EVAP.
NEUTRE 230V → ALARME

DESSINE :	TC	D	04/02/2010	MODIFS DISJONCTEURS	TC
VERIFIE :	TC	C	08/01/2008	MODIF. RC	TC
DATE DE CREATION :		B	19/01/2007	INTEGRATION DISJ. CDE	TC
		A	27/04/2006	EDITION ORIGINAL	TC
INDICE		DATE		MODIFICATION	VISA

Dossier n° :